

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	08 - Kootenay Lake
School Name:	Blewett Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems RECOMMENDATION: Increase supply of outside air RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Date of last inspection: 2025 – October
	Date of next inspection: 2026 - January
	Date and type of most recent maintenance: Replaced filters MERV 13
	Yes/No: Yes
	Detail: Outdoor air set at minimum of 30% during occupied hours
	Yes/No: Yes
	Detail (Including filter grade): MERV13 filters installed
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: DDC designed to manage HVAC energy usage
Other Relevant Information:	Monitor equipment operation via DDC control system to ensure correct operation
District Contact for any Questions:	Name: Chris Kerr
	Phone Number: 250-354-4871
	Email: chris.kerr@sd8.bc.ca

